

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Richard J. Leinenkugel, Secretary

March 16, 2010

LEDGEVIEW PRECAST CONCRETE, INC. ALLEN E. FREUND N6672 COUNTY TRUNK UU FOND DU LAC WI 54937

Re: Description: SEWAGE TREATMENT APPARATUS, FILTER CONTAINER/VAULT

Manufacturer: LEDGEVIEW PRECAST CONCRETE, INC.

Product Name: FILTER CANISTER

Model Number(s): NONE

[34 IN. L.L.; MAX. DEPTH OF BURY = 96 IN.]

Product File No: 20100113

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of JUNE 2014.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Two inch PVC cast in riser for electrical wiring.
 - Press Seal " "Cast-A-Seal" .
 - Dual inlets at end of tank with an access opening above one inlet and an observation opening over the other inlet.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Tank bedding and burial depth: A minimum of 4 in. of ¾ in. clear stone overlying a firm uniform base. Bedding should be level around the perimeter and concave at the middle. For tank burial depths greater than 48 in., contact manufacturer for alternate installation instructions.

This approval supersedes the approval issued on 6/7/2004 under product file number 20040321.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #20040321.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST Engineering Consultant--P

Engineering Consultant--Plumbing Product Review

Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658

Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@WI.GOV

SBD-10564-E (N.10/97) File Ref: 10011303.DOC